

BAR = 1" AT PLOT SCALE

INTL REF: M:\projects\2487108-Details\Working\2-74.dgn

STD: C-0801-11X8A

PIPE ZONE AGGREGATE FOR MAIN LINE AND SERVICE SEWER PIPE PER STD. NO. 2-71

ENGINEER APPROVED COMPATIBLE SADDLE, STRAP, AND APPURTENANCES INSTALLED PER MANUFACTURER'S RECOMMENDATIONS. OPENING IN MAIN LINE PIPE SHALL BE NEATLY FIELD CUT BY ENGINEER APPROVED METHOD AND BE FREE OF JAGGED EDGES.

MAIN LINE SEWER

PAY ITEM FOR MAIN LINE WYE BRANCH

PAY ITEM FOR SERVICE SEWER

6" DIAMETER SERVICE SEWER BY CONTRACTOR TO HERE

EXISTING OR FUTURE SERVICE SEWER BY CUSTOMER

6" PLUG OR RECONNECTION BY CONTRACTOR

3' MIN.

ADDITIONAL FOOTAGE AS REQ'D BY PLANS OR ENGR.

ELEV. AS REQUIRED

1 % MIN. SLOPE

6" BENDS AS REQUIRED TO GAIN PROPER SLOPE AND DIRECTION

* NOT PERMITTED ON NEW LINE CONSTRUCTION

TYPE III SERVICE CONNECTION USING SADDLE



Chester Engineers
260 Airside Drive, Moon Twp., PA 15108-2793
(412)809-6600 FAX(412)809-6611
www.chester-engineers.com

Drawing
2-74

SCALE:

NONE

DATE:

01/07

SHEET:

2 OF 2

STD. NO.

2-74

McCANDLESS TOWNSHIP SEWER AUTHORITY
ALLEGHENY COUNTY, PENNSYLVANIA
SANITARY SERVICE CONNECTIONS
USING WYE FITTINGS,
SADDLE, OR MANHOLE